



SAGE Monthly Security / Firmware Update Notice

Post Date: 5/31/2018

Update Summary:

On May 4, 2018, we released C3414-500-S02K2_P4, which fixed a bug in the local authentication that was introduced in the previous patch, C3414-500-S02K2_P3. If a user tries to log in with a username that does not exist in that RTU's user database, one of the web server tasks would crash. There are 5 web server tasks running in the RTU so after five failed attempts, the RTU would need to be rebooted for the Web GUI to function properly. All SCADA / RTU functionality will continue to work properly, just the configuration interface was affected.

This only affects RTU's running the C3414-500-S02K2_P3 firmware, so we advise anyone running this firmware to update to C3414-500-S02K2_P4.