



SAGE Monthly Security / Firmware Update Notice

Post Date: 12/1/2021

Summary of security related changes for November 2021.

Security Enhancement Summary:

K5_P6 Update – 5-Nov-2021:

NOTE: For use with “LX-800” CPU (C3414) ONLY. Will not work with 5X86 (C3413) or 486 and disk on chip configuration (C3412).

Operating System

Must update OPERATING SYSTEM to use this update!

NOTE: Due to California 2020 cyber-security regulations, users must immediately change the user access account from the default using the Sage User Manager tool. The user account file named “Schneider_Electric_1_USERS.tar.gz” located in the “FW_Update/Secure/updateGen” directory, only has up/download permission to enforce this policy, is delivered on new RTUs and installed when using the Initial Installer to convert a G3_P6 or earlier revision. The user account file named “Schneider_Electric_2.tar.gz”, located in the same path, has the old default “Admin” credentials. Use this user account file at your own risk.

Security Fix Summary:

K5_P6 Update – 5-Nov-2021:

NOTE: For use with “LX-800” CPU (C3414) ONLY. Will not work with 5X86 (C3413) or 486 and disk on chip configuration (C3412).

Operating System

Must update OPERATING SYSTEM to use this update!

Fixes:

☒ Command Log: Fix issue with large number of old command log files causing CPU performance to degrade on startup as command log filenames get cataloged and listed into download menu. Very disk intensive process caused slowdown in GUI performance and configuration downloads. New limit imposed on number of command log files 744 files - 31 days of command log files created once per hour (24 * 31) - is enforced at startup. **NOTE: Download any unsaved Command Log files prior to this update. Automatic enforcement of new limitation on number of files may cause unsaved Command Log files to be deleted at startup.**